



301 N. Hillcrest
Sulphur Springs, TX 75482

2000 I-30 E
Greenville, TX 75402

108 W. Marble
Wylie, TX 75098

Friday, August 28, 2020

Office of Hopkins County Judge
PO Box 288
Sulphur Springs TX 75483

Farmers Electric Cooperative Member: MARIA TOVAR
Service Order Number: 2020083710

Greetings:

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross County Road 2333 which is located 2176' NE OF CR 2332 in Hopkins County, Texas.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossings will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact me at any time.

Sincerely,

Tamara Williams
Project Coordinator
twilliams@farmerselectric.coop
Phone 903-513-2903


Submitted by Psalm Harper
pharper@farmerselectric.coop
Field Engineering Coordinator

Enclosures

County Approval Section:

Approved: ✓ Denied: _____

Authorized Signature: *Psalm Harper* Date: _____



477 ACSR

7.2K

Install
50amp
Fuse



reduced
tension
span

CR 2333

Protective
Device
is OCR



1/0 ACSR

2 TPX

swmh

Location is 2176' Northeast of CR 2332

100ft

entrance

COMO-PICKTON ISD

9

OPKINS EAST SERVICE AREA

MARTIN ALLAIN

NORTH EAST SERVICE AREA

133570

133571

133572

133573

133574

County Road 2333

Crossing at Pole 133571 which is 2176' NE of CR
2332

460450061

23460450062