

David Caceres
Associate Designer

Oncor Electric Delivery
111 Heritage Court
Sulphur Springs, TX 75482
TEL: 469.507.8992 cell
David.Caceres@oncor.com

January 8th, 2025

Hopkins County Courthouse
118 Church St.
Sulphur Springs, TX 75482

Greetings,

Oncor Electric Delivery is requesting permission to construct electric distribution facilities along CR 1178. Construction prints are attached and all facilities meet clearance requirements of 22 ft.

Scope of Work: Install 1 - 40' / 3 pole along CR 1178 at approx. 33.027978, -95.611989. Replace 1 - 40' / 3 with a 45' / 3. This work is being done due to having two poles at lower elevation with primary crossing a hill, this will assist with raising the primary and make sure we are reaching at required clearances. No crossings, this is all parallel to CR 1178. Tree trimming will also be needed.

Should you need anything further, please do not hesitate to contact me.






Best regards,

David Caceres
Associate Designer

Approve Deny

Authorized Signature David Caceres Date 1-8-25

LEGEND

-  OH PRIMARY (TO REMAIN)
-  EXISTING POLE (TO BE REPLACED)
-  POLE (TO BE INSTALLED)
-  DOWN GUY (TO BE REPLACED)
-  Tree Trimming



The underlying image is copyrighted and owned by Google and/or its licensors. This design is provided for illustration purposes only and is not representative of actual size or scale. No copyright notices contained within this design illustration may be removed.



ELECTRIC DELIVERY

ADDRESS: 423 County Road
1178, Sulphur Springs, TX
75482

WO: 27326873

PM: David Caceres



David Caceres
Associate Designer

Oncor Electric Delivery
111 Heritage Court
Sulphur Springs, TX 75482
TEL: 469.507.8992 cell
David.Caceres@oncor.com

January 8th, 2025

Hopkins County Courthouse
118 Church St.
Sulphur Springs, TX 75482

Greetings,

Oncor Electric Delivery is requesting permission to construct electric distribution facilities along CR 4744.

Construction prints are attached and all facilities meet clearance requirements of 22 ft.

Scope of Work: Install 1 - 40/3 pole along county road, near customer property corner, at approx. 33.241136, -95.705250 and two poles on customers property in order to provide electrical service.

Should you need anything further, please do not hesitate to contact me.

Best regards,

David Caceres
Associate Designer








Approve Deny


Authorized Signature

Date

1-8-25

LEGEND

-  OH PRIMARY (TO REMAIN)
-  OH PRIMARY (TO BE INSTALLED)
-  EXISTING POLE (TO REMAIN)
-  POLE (TO BE INSTALLED)
-  NEW OH TRANSFORMER BANK
-  NEW OVERHEAD SERVICE
-  DOWN GUY (TO BE INSTALLED)



The underlying image is copyrighted and owned by Google and/or its licensors. This design is provided for illustration purposes only and is not representative of actual size or scale. No copyright notices contained within this design illustration may be removed.



ELECTRIC DELIVERY

ADDRESS: 4429 CR 4744,
Sulphur Springs, TX 75482

WO:27283700

PM: David Caceres