

111 Heritage Court Sulphur Springs, TX 75482

TEL: 469.507.8992 cell David.Caceres@oncor.com

April 11, 2025

Hopkins County Courthouse 118 Church St. Sulphur Springs, TX 75482

Greetings,

Oncor Electric Delivery is requesting permission to construct electric distribution facilities along CR 4616.

Construction prints are attached and all facilities meet clearance requirements of 22 ft.

Scope of Work: Oncor to replace four existing poles with 45'/3 poles, remove one idle pole and overhead primary, replace two transformers and trim trees along one span of overhead primary. Customers have been notified.

Should you need anything further, please do not hesitate to contact me.

Best regards,

David Caceres Associate Designer

Approve

Deny

Authorized Signature

Date 4-/4-2)

LEGEND

OH PRIMARY (TO REMAIN)

OH PRIMARY (TO BE REMOVED)

■ EXISTING POLE (TO REMAIN)


■ EXISTING POLE (TO BE REPLACED)

EXISTING POLE (TO BE REMOVED)

OH TRANSFORMER (TO BE REPLACED)

TREE TRIMMING

NEW GUY AND ANCHOR





The underlying image is copyrighted and owned by Google and/or its licensors. This design is provided for illustration purposes only and is not representative of actual size or scale. No copyright notices contained within this design illustration may be removed.



ADDRESS: 681 Co Rd 4616, Sulphur Springs, TX 75482

WO: 27605802

PM: David Caceres