

**Oncor Electric Delivery** 111 Heritage Court Sulphur Springs, TX 75482

TEL: 469.507.8992 cell David.Caceres@oncor.com

June 13th, 2025

Hopkins County Courthouse 118 Church St. Sulphur Springs, TX 75482

Greetings,

Oncor Electric Delivery is requesting permission to construct electric distribution facilities along CR 3569.

Construction prints are attached and all facilities meet clearance requirements of 22 ft.

Scope of Work: Install one 45'/3 pole, within an existing span, bring primary across the road and set a 45'/3 pole on the customers property. Tree trimming will be needed along the existing span, and all other work will be underground on the customers property.


Should you need anything further, please do not hesitate to contact me.

Best regards,

David Caceres Associate Designer

Approve\_\_\_\_\_ Deny\_\_\_\_\_
Authorized Signature\_\_\_\_\_\_

Date 6-13-2025





Oncor Electric Delivery
111 Heritage Court
Sulphur Springs, TX 75482

TEL: 469.507.8992 cell David.Caceres@oncor.com

June 16th, 2025

Hopkins County Courthouse 118 Church St. Sulphur Springs, TX 75482

Greetings,

Oncor Electric Delivery is requesting permission to construct electric distribution facilities along CR 4744.

Construction prints are attached and all facilities meet clearance requirements of 22 ft.

Scope of Work: Install 1-45/3 pole along county road, and two poles on customers property in order to provide electrical service

Should you need anything further, please do not hesitate to contact me.

Best regards,

David Caceres Associate Designer

Approve

Denv

Authorized Signature\_

Justin Date 6-17-25

## 4744 OH TRANSFORMER (TO BE INSTALLED) OH SVC LINE (TO BE INSTALLED) OH PRIMARY (TO BE INSTALLED) EXISTING POLE (TO REMAIN) OH PRIMARY (TO REMAIN) NEW GUY AND ANCHOR NEW POLE



ADDRESS: 4301 CR 4744, Sulphur Springs, TX 75482

The underlying image is copyrighted and owned by Google and/or its licensors. This design is provided for illustration purposes only and is not representative of actual size or

ELECTRIC DELIVERY

contained within this design illustration may be removed.

PM: David Caceres

WO: 28955563