


2000 I-30 E Greenville, TX 75402

Tuesday, September 2, 2025 County: Hopkins County Farmers Electric Cooperative Member: Levin Moses Service Order Number: 2025075877 Greetings: Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross County Road 1126. Site location map/construction sketches are attached. The construction sketch details the proposed work. The proposed electrical service will be constructed: ☑ Overhead - All road crossings will have a minimum vertical clearance of 22 feet. ☐ Underground - All underground bore crossings are PVC encased 4' of coverage from the lowest point of the Right of Way. If you have any questions, please contact me at any time. Sincerely, Linda Graham lgraham@farmerselectric.coop **Engineering Coordinator Enclosures** County Approval Section: Approved: \_\_\_\_\_ Denied: \_\_\_\_\_

Authorized Signature: Weyn \_\_\_\_ Date: 9-8-25





2000 I-30 E Greenville, TX 75402

Monday, October 25, 2021 County: Hopkins County Farmers Electric Cooperative Member: LORD'S MEADOWS Service Order Number: 2025021715 Greetings: Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross County Road 4510. Site location map/construction sketches are attached. The construction sketch details the proposed work. The proposed electrical service will be constructed: ☑ Overhead - All road crossings will have a minimum vertical clearance of 22 feet. ☐ Underground - All underground bore crossings are PVC encased 4' of coverage from the lowest point of the Right of Way. If you have any questions, please contact me at any time. Sincerely, Brandon Darrow bdarrow@farmerselectric.coop **Engineering Coordinator Enclosures** County Approval Section: Approved: \_\_\_\_\_ Denied: \_\_\_\_\_ Date: 9-8-25 Approved:

