



2000 I-30 E
Greenville, TX 75402

Thursday, September 11, 2025

County: Hunt County

Farmers Electric Cooperative Member: ASHLEE WILKINS
Service Order Number: 2025072351

Greetings:

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross County Road 2428 APPROX .66 MILES EAST OF CR 2427 (BORE WAS ALREADY COMPLETED WITH APPROVAL FROM GREG ANGLIN DUE TO TIME CONSTRAINTS – WILL BE PUSHING WIRE ON THIS JOB.

Site location map/construction sketches are attached. The construction sketch details the proposed work. The proposed electrical service will be constructed:

- ☐ Overhead - All road crossings will have a minimum vertical clearance of 22 feet.
☒ Underground - All underground bore crossings are PVC encased 4' of coverage from the lowest point of the Right of Way.

If you have any questions, please contact me at any time.


Sincerely,

Psalm Harper
pharper@farmerselectric.coop
Engineering Coordinator

Enclosures

County Approval Section:

Approved: ☒ Denied: ☐

Authorized Signature: 

Date: 9-15-25

THERE IS WHITE FLAGGING
ALONG THE FENCE TO MARK
STAKE LOCATIONS

(2) 3" STUB OUTS
FOR PERM SERVICE

PATH WILL NEED TO BE
CLEARED AS TRENCHING

DIRT DRIVE

DEAD TREE

LAY PIPE IN SAME TRENCH

2" STUB OUT
FOR FUTURE SERVICE
TO NEXT PROPERTY

FOLLOW STAKES TO AVOID CR 2428

LARGE TREES

THERE ARE SMALL TREES THAT WILL NEED
TO BE TAKEN OUT

AHATHCOAT & MBR IS AWARE OF US DOING THE CLEARING
*THERE IS ONE DEAD TREE
THAT CAN BE TAKEN OUT*

